



Side channel pump

Original Operating Manual

SON, SOB, SRN, SRB, SRBS
SOH, SOHB, SFH, SOR, SVG
SRZ, SRZS
SOHM, SVM
SEMA-L, SEMA-Z, SEMA-S



Version BA-2010.02
Print-No. S-EN

We reserve the right to make technical changes.



Table of contents

| | | | | | |
|----------|--|----|----------|--|----|
| 1 | About this document | 5 | 5.2 | Planning the pipes | 21 |
| 1.1 | Target groups | 5 | 5.2.1 | Specifying supports and flange connections | 21 |
| 1.2 | Other applicable documents | 5 | 5.2.2 | Specifying nominal diameters | 21 |
| 1.3 | Warnings and symbols | 6 | 5.2.3 | Specifying pipe lengths | 21 |
| 1.4 | Technical terms | 6 | 5.2.4 | Determining the suction pipe | 21 |
| 2 | Safety | 7 | 5.2.5 | Optimizing changes in cross-section and direction | 21 |
| 2.1 | Intended use | 7 | 5.2.6 | Optimizing supply ratios | 21 |
| 2.2 | General safety instructions | 7 | 5.2.7 | Providing safety and control devices (recommended) | 22 |
| 2.2.1 | Product safety | 7 | 5.2.8 | Installation recommendations | 23 |
| 2.2.2 | Obligations of the operating company | 8 | 5.3 | Installation on a foundation | 24 |
| 2.2.3 | Obligations of personnel | 8 | 5.3.1 | Preparing the pump unit | 24 |
| 2.3 | Specific hazards | 8 | 5.3.2 | Setting the pump unit on the foundation | 24 |
| 2.3.1 | Explosion-hazard area | 8 | 5.3.3 | Fastening the pump unit | 24 |
| 2.3.2 | Hazardous pumped liquids | 8 | 5.4 | Connecting the pipes | 25 |
| 2.3.3 | Magnetic field | 8 | 5.4.1 | Keeping the pipes clean | 25 |
| 3 | Layout and function | 9 | 5.4.2 | Installing auxiliary piping | 25 |
| 3.1 | Label | 9 | 5.4.3 | Installing the suction pipe | 25 |
| 3.1.1 | Type plate | 9 | 5.4.4 | Installing the pressure pipe | 25 |
| 3.1.2 | Pump type code | 9 | 5.4.5 | Checking the stress-free pipe connections | 25 |
| 3.1.3 | Other signs at the pump | 10 | 5.5 | Installing the motor | 25 |
| 3.1.4 | ATEX plate | 10 | 5.6 | Aligning the coupling precisely | 26 |
| 3.2 | Layout | 11 | 5.7 | Aligning the motor | 27 |
| 3.3 | Variants | 13 | 5.7.1 | Aligning the motor with sets of shims | 27 |
| 3.3.1 | Variants with a mechanical seal | 13 | 5.8 | Electrical connection | 27 |
| 3.3.2 | Variants with a magnetic coupling | 15 | 5.8.1 | Connecting the motor | 27 |
| 3.4 | Shaft seals | 15 | 6 | Operation | 28 |
| 3.4.1 | Stuffing box packings | 15 | 6.1 | Putting the pump into service for the first time | 28 |
| 3.4.2 | Mechanical seals | 15 | 6.1.1 | Performing the pressure test | 28 |
| 3.4.3 | Magnetic coupling | 15 | 6.1.2 | Identifying the pump type | 28 |
| 3.5 | Auxiliary operating systems | 15 | 6.1.3 | Removing the preservative | 28 |
| 3.5.1 | Sealing systems | 15 | 6.1.4 | Preparing auxiliary systems (if available) | 28 |
| 3.6 | Bearings and lubrication | 16 | 6.1.5 | Filling and bleeding | 28 |
| 4 | Transport, storage and disposal | 17 | 6.1.6 | Checking the sense of rotation | 29 |
| 4.1 | Transport | 17 | 6.2 | Start-up | 29 |
| 4.1.1 | Unpacking and inspection on delivery | 17 | 6.2.1 | Switching on | 29 |
| 4.1.2 | Lifting | 17 | 6.2.2 | Changing the operating parameters | 30 |
| 4.2 | Treatment for storage | 18 | 6.2.3 | Switching off (temporarily) | 30 |
| 4.2.1 | Applying preservative to the inside | 18 | 6.3 | Shutting down the pump | 31 |
| 4.2.2 | Applying preservative to the outside | 18 | 6.4 | Start-up following a shutdown period | 32 |
| 4.3 | Storage | 18 | 6.5 | Operating the stand-by pump | 32 |
| 4.4 | Removing the preservative | 19 | 7 | Maintenance | 33 |
| 4.5 | Disposal | 19 | 7.1 | Inspections | 33 |
| 5 | Setup and connection | 20 | 7.2 | Maintenance | 34 |
| 5.1 | Preparing the setup | 20 | 7.2.1 | Bearing | 34 |
| 5.1.1 | Checking the ambient conditions | 20 | 7.2.2 | Mechanical seals | 34 |
| 5.1.2 | Preparing the installation site | 20 | 7.2.3 | Coupling | 34 |
| 5.1.3 | Preparing the foundation and surface | 20 | | | |
| 5.1.4 | Removing the preservative | 20 | | | |
| 5.1.5 | Installing the heat insulation | 20 | | | |

| | | |
|----------|---|-----------|
| 7.2.4 | Cleaning the pump | 35 |
| 7.3 | Dismounting | 35 |
| 7.3.1 | Dismounting | 36 |
| 7.3.2 | Returning the pump to the manufacturer | 36 |
| 7.4 | Installing | 37 |
| 7.5 | Ordering spare parts | 37 |
| 8 | Troubleshooting | 38 |
| 8.1 | Pump malfunctions | 38 |
| 9 | Appendix | 41 |
| 9.1 | Technical specifications | 41 |
| 9.1.1 | Ambient conditions | 41 |
| 9.1.2 | Weight | 41 |
| 9.1.3 | Sound pressure level | 41 |
| 9.2 | Safety certificate | 42 |
| 9.3 | Declarations according to EC machine directives | 43 |
| 9.3.1 | Declaration of conformity according to EC machine directives | 43 |
| 9.3.2 | Declaration of installation according to EC machine directive | 44 |
| 9.4 | Short instructions for commissioning a pump unit delivered complete | 45 |
| 9.5 | ATEX additional instructions | 46 |
| 9.5.1 | Safety | 46 |
| 9.5.2 | Explosion protection mark | 46 |
| 9.5.3 | Installation and connection | 48 |
| 9.5.4 | Operation | 49 |
| 9.5.5 | Maintenance | 50 |

List of figures

| | | |
|---------|---|----|
| Fig. 1 | Type plate (example) | 9 |
| Fig. 2 | ATEX plate (example) | 10 |
| Fig. 3 | Side channel pump characteristics | 11 |
| Fig. 4 | Construction (example) | 12 |
| Fig. 8 | Straight pipe lengths upstream and downstream of the pump (recommended) | 21 |
| Fig. 9 | Installation example | 23 |
| Fig. 13 | Sound pressure level | 41 |
| Fig. 14 | Explosion protection labeling on the pump (equipment group II, category 2) | 46 |
| Fig. 15 | Explosion protection labeling on the pump (equipment group II, category 3) | 46 |

List of tables

| | | |
|---------|---|----|
| Tab. 1 | Target groups and their duties | 5 |
| Tab. 2 | Other applicable documents and their purpose | 5 |
| Tab. 3 | Warnings and consequences of disregarding them | 6 |
| Tab. 4 | Symbols and their meaning | 6 |
| Tab. 5 | Technical terms and their meaning | 6 |
| Tab. 6 | Signs at the pump | 10 |
| Tab. 7 | Variants with a mechanical seal | 14 |
| Tab. 8 | Variants with a magnetic coupling | 15 |
| Tab. 9 | Coupling setting | 26 |
| Tab. 10 | Measures to be taken if the pump is shut down | 31 |
| Tab. 11 | Measures depending on the behavior of the pumped liquid | 31 |
| Tab. 12 | Measures to be taken after prolonged shutdown periods | 32 |
| Tab. 13 | Coupling wear | 34 |
| Tab. 14 | Measures for returning the pump | 36 |
| Tab. 15 | Troubleshooting list | 40 |
| Tab. 16 | Ambient conditions | 41 |
| Tab. 17 | Safety certificate | 42 |
| Tab. 18 | Declaration of conformity according to EC machine directives | 43 |
| Tab. 19 | Declaration of installation according to EC Machine Directive | 44 |
| Tab. 20 | Temperature class | 46 |
| Tab. 21 | Type of protection against ignition | 47 |
| Tab. 22 | Ex atmosphere | 47 |
| Tab. 23 | Equipment group / area of use / zone / category | 47 |
| Tab. 24 | Possible control measures to avoid dry running with resulting impermissible overheating | 48 |
| Tab. 25 | Measures to prevent impermissible overheating | 49 |
| Tab. 26 | Max. pumped liquid temperature | 49 |
| Tab. 27 | Max. heating medium temperature | 49 |

1 About this document

This manual:

- Is part of the pump
- Applies to the pump series mentioned above
- Describes safe and appropriate operation during all operating phases

1.1 Target groups

| Target group | Duty |
|-----------------------------|---|
| Operating company | <ul style="list-style-type: none"> ► Keep this manual available at the site of operation of the equipment, including for later use. ► Ensure that personnel read and follow the instructions in this manual and the other applicable documents, especially all safety instructions and warnings. ► Observe any additional rules and regulations referring to the system. |
| Qualified personnel, fitter | <ul style="list-style-type: none"> ► Read, observe and follow this manual and the other applicable documents, especially all safety instructions and warnings. |

Tab. 1 Target groups and their duties





1.2 Other applicable documents

| Document | Purpose |
|--|--|
| Data sheet | Technical specifications, conditions of operation |
| Dimension drawing ¹⁾ | Setup dimensions, connection dimensions etc. |
| Delivery note | Details on scope of delivery, weight, etc. |
| Sectional drawing, spare parts list ¹⁾ | Ordering spare parts |
| Supplier documentation | Technical documentation for parts supplied by subcontractors |
| Declaration of conformity, declaration of installation | Conformity with standards, contents of the declarations of conformity and installation (→ 9.3 Declarations according to EC machine directives, Page 43). |



Tab. 2 Other applicable documents and their purpose

1) Can be subsequently ordered if necessary.

1.3 Warnings and symbols

| Warning | Risk level | Consequences of disregarding the warning |
|---|---------------------------------|--|
|  | Immediate acute risk | Death, serious bodily harm |
|  | Potential acute risk | Death, serious bodily harm |
|  | Potentially hazardous situation | Minor bodily harm |
|  | Potentially hazardous situation | Material damage |

Tab. 3 Warnings and consequences of disregarding them

| Symbol | Meaning |
|---|--|
|  | Safety warning sign ► Take note of all information highlighted by the safety warning sign and follow the instructions to avoid injury or death. |
| ► | Instruction |
| 1. , 2. , ... | Multiple-step instructions |
| ✓ | Precondition |
| → | Cross reference |
|  | Information, notes |

Tab. 4 Symbols and their meaning

1.4 Technical terms

| Term | Meaning |
|-----------------------------|--|
| Sealing medium | Medium for blocking or quenching shaft seals |
| Auxiliary operating systems | Systems for operating the pump |

Tab. 5 Technical terms and their meaning

2 Safety



The manufacturer does not accept any liability for damages caused by disregarding the entire documentation.

2.1 Intended use

- Only use the pump to pump the agreed pumped liquids (→ data sheet).
- Adhere to the operating limits and size-dependent minimum flow rate (→ data sheet).
- Avoid dry running:
 - Initial damage, such as destruction of seals and plastic parts, will occur within only a few seconds.
 - Make sure the pump is only operated with, and never without, pumped liquid.
- Avoid cavitation:
 - Open the suction-side fitting completely.
 - Do not open the pressure-side fitting beyond the agreed operating point (→ data sheet).
- Avoid overheating:
 - Do not operate the pump while the pressure-side fitting is closed.
 - Observe the minimum flow rate (→ data sheet).
- Avoid damage to the motor:
 - Do not open the pressure-side fitting beyond the agreed operating point.
 - Note the maximum permissible number of times the motor can be switched on per hour (→ manufacturer's specifications).
- Consult the manufacturer about any other use of the pump.

Prevention of obvious misuse (examples)

- Note the operating limits of the pump concerning temperature, pressure, flow rate and motor speed (→ data sheet).
- The power consumed by the pump increases with increasing density of the pumped medium. To avoid overloading the pump, coupling or motor, stay within the agreed density (→ data sheet).
Lower densities are allowed. Adapt the auxiliary systems accordingly.
- When using auxiliary systems, ensure there is a continuous supply of the appropriate operating medium.
- Pumps may not be used with foodstuffs if they have not been adapted accordingly. The use of the pump for foodstuffs must be specified in the data sheet.
- Only select the setup type according to this operating manual. For example, the following are not allowed:
 - Hanging base plate pumps in the pipe
 - Overhead installation
 - Installation in the immediate vicinity of extreme heat or cold sources
 - Installation too close to the wall

2.2 General safety instructions



Observe the following regulations before carrying out any work.

2.2.1 Product safety

The pump has been constructed according to the latest technology and recognized technical safety rules. Nevertheless, operation of the pump can still put the life and health of the user or third parties at risk or damage the pump or other property.

- Only operate the pump if it is in perfect technical condition and only use it as intended, remaining aware of safety and risks, and in adherence to the instructions in this manual.
- Keep this manual and all other applicable documents complete, legible and accessible to personnel at all times.
- Refrain from any procedures and actions that would pose a risk to personnel or third parties.
- In the event of any safety-relevant malfunctions, shut down the pump immediately and have the malfunction corrected by the personnel responsible.
- In addition to the entire documentation for the product, comply with statutory or other safety and accident-prevention regulations and the applicable standards and guidelines in the country where the pump is operated.

2.2.2 Obligations of the operating company

Safety-conscious operation

- Only operate the pump if it is in perfect technical condition and only use it as intended, remaining aware of safety and risks, and in adherence to the instructions in this manual.
- Ensure that the following safety aspects are observed and monitored:
 - Adherence to intended use
 - Statutory or other safety and accident-prevention regulations
 - Safety regulations governing the handling of hazardous substances
 - Applicable standards and guidelines in the country where the pump is operated
- Make personal protective equipment available.

Qualified personnel

- Make sure all personnel tasked with work on the pump have read and understood this manual and all other applicable documents, especially the safety, maintenance and repair information, before they start any work.
- Organize responsibilities, areas of competence and the supervision of personnel.
- Ensure that all work is carried out by specialist technicians only:
 - Fitting, repair and maintenance work
 - Work on the electrical system
- Make sure that trainee personnel only work on the pump under the supervision of specialist technicians.
- Persons who have an implanted pacemaker:
 - Must stay away from the pump with magnetic coupling and parts of the magnetic coupling
 - May not work on or with any of the magnetic parts

Safety equipment

- Provide the following safety equipment and verify its functionality:
 - For hot, cold and moving parts: Safety guarding provided by the customer for the pump
 - For possible build up of electrostatic charge: Ensure appropriate grounding

Warranty

- Obtain the manufacturer's approval prior to carrying out any modifications, repairs or alterations during the warranty period.
- Only use genuine parts or parts that have been approved by the manufacturer.

2.2.3 Obligations of personnel

- All directions given on the pump must be followed (and kept legible), e.g. the arrow indicating the sense of rotation and the markings for fluid connections.
- Pump, contact guard and components:
 - Do not step on them or use as a climbing aid
 - Do not use them to support boards, ramps or beams
 - Do not use them as a fixing point for winches or supports
 - Do not use them for storing paper or similar materials
 - Do not use hot pump or motor components as a heating point
 - Do not de-ice using gas burners or similar tools
- Do not remove the safety guarding for hot, cold or moving parts during operation.
- Use personal protective equipment whenever necessary.
- Only carry out work on the pump while it is not running.
- Isolate the motor from its supply voltage and secure it against being switched back on again before all assembly and maintenance work.
- Reinstall the safety equipment on the pump as required by regulations after any work on the pump.
- With an implanted pacemaker:
 - Stay at least 1 meter away from the pump with magnetic coupling or parts of the magnetic coupling.
 - Do not work with or on the magnetic parts.

2.3 Specific hazards

2.3.1 Explosion-hazard area

- (→ 9.5 ATEX additional instructions, Page 46).

2.3.2 Hazardous pumped liquids

- Follow the safety regulations for handling hazardous substances when handling hazardous (e.g. hot, flammable, poisonous or potentially harmful) pumped liquids.
- Use personal protective equipment when carrying out any work on the pump.

2.3.3 Magnetic field

The magnetic field of the magnetic coupling can destroy products that are sensitive to magnets. These include:

- Pacemakers
- Plastic identity cards with magnetic strips
- Credit and check cards
- Electric, electronic and precision mechanical devices (such as mechanical and digital clocks, pocket calculators, hard disks)

3 Layout and function

3.1 Label

3.1.1 Type plate

| | | | | | |
|------------|---|-------------------|-----|-------------------|---|
| Hersteller | | | | | |
| Nr. | | | | | |
| 8 | Q | m ³ /h | H | mFIS | 3 |
| 7 | t | °C | n | min ⁻¹ | 4 |
| 6 | P | kW | Bj. | 20 | 5 |

Fig. 1 Type plate (example)

- 1 Name
- 2 Serial number
- 3 Differential head
- 4 Motor speed
- 5 Year of manufacture
- 6 Output (motor)
- 7 Max. pumped liquid temperature
- 8 Flow rate

3.1.2 Pump type code

- SON...W, SOHN...WW
 - Self-priming side channel pump PN 16, capable of handling aerated fluids (light-weight version)
 - Horizontal, single-stage or multi-stage
 - Base plate version (pump and motor on shared base plate)
- SOB...W
 - Self-priming side channel pump PN 16, capable of handling aerated fluids (light-weight version)
 - Horizontal, single-stage or multi-stage
 - Block version with flange-mounted motor
- SRN...WW
 - Self-priming side channel pump PN 25, capable of handling aerated fluids (medium-weight version)
 - Horizontal, single-stage or multi-stage
 - Base plate version (pump and motor on shared base plate)
- SRB...WW
 - Self-priming side channel pump PN 25, capable of handling aerated fluids (medium-weight version)
 - Horizontal, single-stage or multi-stage
 - Block version with flange-mounted motor
- SRBS...W
 - Multifunction pump – pump combining a side channel pump and a centrifugal pump
 - Side channel pump PN 25, capable of handling aerated fluids (medium-weight version)
 - Horizontal, single-stage and multi-stage
 - With upstream suction impeller and axial suction branch to achieve lower NPSH values
 - Block version with flange-mounted motor
- SOH...W
 - Self-priming side channel pump PN 16, capable of handling aerated fluids (light-weight version)
 - Horizontal, single-stage or multi-stage
 - Base plate version (pump and motor on shared base plate)
- SOHB...W
 - as SOH...W
 - Block version with flange-mounted motor
- SFH...WW
 - Self-priming side channel pump PN 25, capable of handling aerated fluids (medium-weight version)
 - Horizontal, single-stage and multi-stage
 - Base plate version (pump and motor on shared base plate)
- SOR...W
 - Self-priming side channel pump PN 6, capable of handling aerated fluids
 - Horizontal, single-stage
 - Short design as nozzles are arranged side-by-side, radially upwards
- SVG
 - Self-priming inline side channel pump PN 16, capable of handling aerated fluids
 - Vertical, single-stage
 - Block version with flange-mounted motor
- SRZ...WW
 - Self-priming side channel pump PN 40, capable of handling aerated fluids (heavy version)
 - Horizontal, single-stage and multi-stage
 - Base plate version (pump and motor on shared base plate)
- SRZS...W
 - Multifunction pump – pump combining a side channel pump and a centrifugal pump
 - Side channel pump PN 40, capable of handling aerated fluids (heavy version)
 - Horizontal, single-stage and multi-stage
 - With upstream suction impeller and axial suction branch to achieve lower NPSH values
 - Base plate version (pump and motor on shared base plate)
- SOHM
 - Self-priming side channel pump PN 16, capable of handling aerated fluids (light-weight version)
 - Horizontal, single-stage or multi-stage
 - Magnetic coupling
 - Block version with flange-mounted motor

- SVM
 - As SVG
 - Magnetic coupling
- SEMA-L/Z (SEMA-L-Block)
 - As SRZ...WW
 - Magnetic coupling
 - SEMA-L: Base plate version (pump and motor coupled flexibly on shared base plate)
 - SEMA-L-Block: Pump and motor on shared base plate, motor flange-mounted to pump directly
- SEMA-S (SEMA-S-Block)
 - As SRZS...W
 - Magnetic coupling
 - SEMA-S: Base plate version (pump and motor coupled flexibly on shared base plate)
 - SEMA-S-Block: Pump and motor on shared base plate, motor flange-mounted to pump directly

3.1.4 ATEX plate




Fig. 2 ATEX plate (example)

- 1 Explosion protection mark
- 2 Reference to ATEX additional instructions
(→ 9.5 ATEX additional instructions, Page 46).

3.1.3 Other signs at the pump

| Picture | Explanation |
|---------|----------------------------------|
| | Sense of rotation arrow |
| | Suction and pressure connection |
| | Strong magnet, magnetic coupling |
| | Auxiliary medium at entrance |
| | Auxiliary medium at exit |

Tab. 6 Signs at the pump

3.2 Layout

Self-priming side channel pump

The side channel pump is suitable for pumping pure and cloudy fluids, as well as those containing gas. The narrow gap clearance means that the pump is not suitable for pumping media with abrasive or aggressive admixtures or solid content.

The pump characteristics of the side channel pump differ greatly from those of a centrifugal pump. As the pressure increases, the motor power required also **increases**.




Fig. 3 Side channel pump characteristics

The following conditions must be observed when operating a side channel pump:

- Start it up only when the pressure-side gate valve is fully open
- Never close the pressure-side gate valve fully
- Observe the flow rate limits (Q_{min} , Q_{max})

The side channel pump can transport air or gases and evacuate a suction pipe. The suction capacity is limited to a vacuumetric suction head of 7 m (at a water temperature of 20 °C). The suction capacity is reduced for pumped liquids at higher temperatures, with a higher specific weight or at lower evaporation pressures.

Maximum suction head and suction time (→ data sheet).












Fig. 4 Construction (example)







- | | | |
|-----------------------------|-------------------|-----------------------------|
| 1 Housing (suction casing) | 4 Foot | 7 Shaft seal housing |
| 2 Housing (pressure casing) | 5 Bearing bracket | 8 Limit for heat insulation |
| 3 Hydraulics | 6 Shaft | |

3.3 Variants

- Horizontal or vertical operation
- Free shaft (without a motor or a base plate)
- Final unit (mounted on base plate, with drive motor, coupling and contact guard)
- With mechanical seal or magnetic coupling







3.3.1 Variants with a mechanical seal

| | | | |
|----------|---|----------|--|
| SON...W |  | SON...WW |  |
| SOB...W |  | SRN...WW |  |
| SRB...WW |  | SRBS...W |  |
| SOH...W |  | SOHB...W |  |

| | | | |
|----------|--|-------------|---|
| SFH...WW |  | SOR...W |  |
| SVG |  | SRZ...WW |  |
| SRZS...W |  | SRZS...W KK |  |


Tab. 7 Variants with a mechanical seal

3.3.2 Variants with a magnetic coupling


| | | | |
|------------------|--|------------------------------|--|
| SOHM |  | SVM |  |
| SEMA-L SEMA-Z |  | SEMA-L-Block SEMA-Z-Block |  |
| SEMA-S |  | SEMA-S-Block |  |

Tab. 8 Variants with a magnetic coupling


3.4 Shaft seals

 Only one of the following shaft seals can be used.

3.4.1 Stuffing box packings


 Stuffing box packings have functional drop leaks.

3.4.2 Mechanical seals

 Mechanical seals have functional drop leaks.

- Single-action mechanical seal
- Double-action mechanical seal

3.4.3 Magnetic coupling

 Magnetic couplings are hermetically sealed.

3.5 Auxiliary operating systems

3.5.1 Sealing systems

Quenching

The pressure of the pumped medium is higher than the pressure of the sealing medium during quenching. Pumped medium penetrates the sealing medium.

Application example: Pumped liquids that can crystallize in the atmosphere and thus cause damage to the seal in the long-term

Blocking

The pressure of the sealing medium is higher than the pressure of the pumped liquid when blocking. The seal surfaces are lubricated by the sealing medium.


Application example: Pumped liquids that can crystallize and thus cause damage to the seal in the long-term

3.6 Bearings and lubrication

- Series SON...W
 - Drive side: single-row groove ball bearing lubricated with grease
 - Outlet flange and intermediate levels: sleeve bearings lubricated by pumped liquid
- Series SON...WW
 - On both sides: single-row groove ball bearings lubricated with grease
 - Intermediate levels: sleeve bearings lubricated by pumped liquid
- Series SOB...W
 - Drive side: single-row groove ball bearing lubricated with grease
 - Outlet flange and intermediate levels: sleeve bearings lubricated by pumped liquid
- Series SRN...WW
 - On both sides: single-row groove ball bearings lubricated with grease
 - Intermediate levels: sleeve bearings lubricated by pumped liquid
- Series SRB...WW
 - On both sides: single-row groove ball bearings lubricated with grease
 - Intermediate levels: sleeve bearings lubricated by pumped liquid
- Series SRBS...WW
 - Drive side: single-row groove ball bearing lubricated with grease
 - Suction side: special carbon sleeve bearing
 - Intermediate levels: sleeve bearings lubricated by pumped liquid
- Series SOH...W, SOHB...W
 - Drive side: single-row groove ball bearing lubricated with grease
 - Outlet flange and intermediate levels: sleeve bearings lubricated by pumped liquid
- Series SFH...WW
 - On both sides: single-row groove ball bearings lubricated with grease
 - Intermediate levels: sleeve bearings lubricated by pumped liquid
- Series SOR
 - Externally: two single-row groove ball bearings lubricated with grease
- Series SVG
 - Drive side: rigid sleeve coupling connected to motor shaft
 - Base: special carbon bearing bush lubricated by pumped liquid
- Series SRZ...WW
 - On both sides: single-row groove ball bearings lubricated with grease
 - Intermediate levels: sleeve bearings lubricated by pumped liquid
- Series SRZS...W
 - Drive side: single-row groove ball bearing lubricated with grease
 - Suction side: special carbon sleeve bearing
 - Intermediate levels: sleeve bearings lubricated by pumped liquid
- Series SOHM
 - Internally: Radial sleeve bearing
 - Intermediate levels: sleeve bearings lubricated by pumped liquid
- Series SVM
 - Below the magnetic coupling: combined axial and radial sleeve bearing
 - Base: special carbon bearing bush lubricated by pumped liquid
- Series SEMA (all variants)
 - Externally: two single-row groove ball bearings lubricated with grease
 - Internally: combined axial and radial sleeve bearing
 - Stage casing and intermediate level: sleeve bearings lubricated by pumped liquid

4 Transport, storage and disposal

4.1 Transport

 Weight specifications (→ delivery note)

DANGER

Risk of death and material damage due to magnetic field!

- ▶ Make sure that personnel who have a pacemaker do not perform any work on the pump.
- ▶ Secure the work area. If necessary isolate the area:
 - Make sure that personnel with pacemakers keep a safe distance of at least 1 meter.
 - Make sure that no magnetizable metal parts can be attracted by the magnetic coupling of the pump.
 - Make sure that parts of the magnetic coupling cannot be attracted by the magnetizable metal parts.
- ▶ Keep all magnetically-sensitive objects at a safe distance of at least 150 mm from the magnetic coupling.

4.1.1 Unpacking and inspection on delivery

1. After receiving the delivery, check that it is complete.
2. Unpack the pump/unit on delivery and inspect it for transport damage.
3. Report any transport damage to the delivery company immediately.
4. Dispose of packaging material according to local regulations.

4.1.2 Lifting

DANGER

Death or crushing of limbs caused by falling loads!

- ▶ Use lifting gear appropriate for the total weight to be transported.
- ▶ Fasten the lifting gear as shown in the following illustrations.
- ▶ Do not stand under suspended loads.

- ▶ Lift the pump/unit properly (see figs).




Fig. 5 Fastening the lifting gear to the pump unit with base plate




Fig. 6 Fastening the lifting gear to the block pump (horizontal variant)





Fig. 7 Fastening the lifting gear to the block pump (vertical variant)

4.2 Treatment for storage

 Pumps made of gray cast iron or spheroidal iron are treated at the plant (→ trailer at the pump)

NOTE

Material damage due to missing or inappropriate treatment for storage!

- Treat the pump properly, inside and outside, for storage.

4.2.1 Applying preservative to the inside

1. Close the suction-side flange with a blank flange.
2. With opposite flanges, turn the pump on the suction flange.
3. Fill pump with suitable preservative
4. Turn the shaft slowly in the pump's sense of rotation.
5. Continue filling and turning until preservative escapes from the pressure flange without bubbles.
6. Close the pressure-side flange with a blank flange.

4.2.2 Applying preservative to the outside

- Apply preservative to all bare metal parts.

4.3 Storage

DANGER

Risk of death and material damage due to magnetic field!


- Make sure that personnel who have a pacemaker do not perform any work on the pump.
- Secure the work area. If necessary isolate the area:
 - Make sure that personnel with pacemakers keep a safe distance of at least 1 meter.
 - Make sure that no magnetizable metal parts can be attracted by the magnetic coupling of the pump.
 - Make sure that parts of the magnetic coupling cannot be attracted by the magnetizable metal parts.
- Keep all magnetically-sensitive objects at a safe distance of at least 150 mm from the magnetic coupling.

NOTE

Material damage due to inappropriate storage!

- Treat and store the pump properly.
1. Seal all openings with blank flanges, blind plugs or plastic covers.
 2. Make sure the storage room meets the following conditions:
 - Dry
 - Frost-free
 - Vibration-free
 3. Turn the shaft once every two months.
 4. Every 6 months:
 - Renew the preservative if necessary.

4.4 Removing the preservative

 Only needed if used in a relevant sector (e.g. food sector) and if the pump has been treated.

WARNING

Risk of poisoning from preservatives and cleaning agents in the foodstuffs and drinking water sector!

- ▶ Only use cleaning agents which are compatible with the pumped liquid.
- ▶ Completely remove all preservative.

NOTE

High water pressure or spray water can damage bearings!

- ▶ Do not clean bearing areas with a water or steam jet.

NOTE

Damage to seals due to wrong cleaning agents!

- ▶ Ensure the cleaning agent does not corrode the seals.
1. Choose the cleaning agent according to the application.
 2. Dispose of preservatives according to local regulations.
 3. For storage times in excess of 6 months:
 - Replace the elastomer parts made of EP rubber (EPDM).
 - Check all elastomer parts (O-rings, shaft seals) for proper elasticity and replace them if necessary.

4.5 Disposal

DANGER

Risk of death and material damage due to magnetic field!


- ▶ Make sure that personnel who have a pacemaker do not perform any work on the pump.
- ▶ Secure the work area. If necessary isolate the area:
 - Make sure that personnel with pacemakers keep a safe distance of at least 1 meter.
 - Make sure that no magnetizable metal parts can be attracted by the magnetic coupling of the pump.
 - Make sure that parts of the magnetic coupling cannot be attracted by the magnetizable metal parts.
- ▶ Keep all magnetically-sensitive objects at a safe distance of at least 150 mm from the magnetic coupling.

WARNING

Risk of poisoning and environmental damage by the pumped liquid!

- ▶ Use personal protective equipment when carrying out any work on the pump.
- ▶ Prior to the disposal of the pump:
 - Collect and dispose of any leaking pumped liquid in accordance with local regulations.
 - Neutralize residues of pumped liquid in the pump.
 - Remove the preservative (→ 4.4 Removing the preservative, Page 19).
- ▶ Dispose of the pump in accordance with local regulations.

5 Setup and connection

 For pumps in explosion-hazard areas (→ 9.5 ATEX additional instructions, Page 46).

Short instructions for trained specialist personnel (→ 9.4 Short instructions for commissioning a pump unit delivered complete, Page 45).

NOTE

Material damage due to distortion or passage of electrical current in the bearing!

- ▶ Do not make any structural modifications to the pump unit or pump casing.
- ▶ Do not carry out any welding work on the pump unit or pump casing.

NOTE

Material damage caused by dirt!

- ▶ Do not remove any covers or transport and sealing covers until immediately before connecting the pipes to the pump.

5.1 Preparing the setup

DANGER

Risk of death and material damage due to magnetic field!

- ▶ Make sure that personnel who have a pacemaker do not perform any work on the pump.
- ▶ Secure the work area. If necessary isolate the area:
 - Make sure that personnel with pacemakers keep a safe distance of at least 1 meter.
 - Make sure that no magnetizable metal parts can be attracted by the magnetic coupling of the pump.
 - Make sure that parts of the magnetic coupling cannot be attracted by the magnetizable metal parts.
- ▶ Keep all magnetically-sensitive objects at a safe distance of at least 150 mm from the magnetic coupling.


5.1.1 Checking the ambient conditions

1. Make sure the required ambient conditions are fulfilled (→ 9.1.1 Ambient conditions, Page 41).
2. For setup altitude > 1000 m above sea level, consult the manufacturer.

5.1.2 Preparing the installation site

- ▶ Ensure the installation site meets the following conditions:
 - Pump is freely accessible from all sides
 - Sufficient space for the installation/removal of the pipes and for maintenance and repair work, especially for the removal and installation of the pump and the motor
 - Pump not exposed to external vibrations (damage to bearings)
 - Frost protection

5.1.3 Preparing the foundation and surface


 Setup options:

- With concrete foundation
 - With steel foundation frame
- ▶ Make sure the foundation and surface meet the following conditions:
 - Level
 - Clean (no oil, dust or other impurities)
 - Capable of bearing the weight of the pump unit and all operating forces
 - The pump is stable and cannot tip over
 - With concrete foundation: standard concrete of strength class B 25

5.1.4 Removing the preservative

- ▶ If the pump is to be put into operation immediately after setup and connection: Remove the preservative prior to setup (→ 4.4 Removing the preservative, Page 19).

5.1.5 Installing the heat insulation

 Only necessary to maintain the temperature of the pumped liquid.

NOTE

Material damage on the bearing or shaft seal due to overheating!

- ▶ Only install the heat insulation on the pump casing (→ 3.2 Layout, Page 11).
- ▶ Install the heat insulation properly.

5.2 Planning the pipes

5.2.1 Specifying supports and flange connections

NOTE

Material damage due to excessive forces and torques exerted by the piping on the pump!

- Do not exceed permissible values (these can be requested from the manufacturer if required).

1. Calculate the pipe forces, taking every possible operating condition into account:
 - Cold/warm
 - Empty/full
 - Depressurized/pressurized
 - Positional changes of the flanges
2. Ensure the pipe supports have permanent low-friction properties and do not seize up due to corrosion.

5.2.2 Specifying nominal diameters

- ◡ Keep the flow resistance in the pipes as low as possible.
- ◡ Flow rate in suction pipe $< 1 \text{ m/s}$

1. Make sure the nominal suction pipe diameter is \geq the nominal suction branch diameter.
2. Make sure the nominal pressure pipe diameter is \geq the nominal outlet flange diameter.

5.2.3 Specifying pipe lengths




Fig. 8 Straight pipe lengths upstream and downstream of the pump (recommended)

A $> 10 \times$ nominal suction pipe diameter

B Nominal suction pipe diameter

- Maintain the recommended minimum values when installing the pump.

- ◡ Suction side: Shorter pipes are possible but may restrict the hydraulic performance.

5.2.4 Determining the suction pipe

1. Suction operation:
 - Place the suction strainer at least 0.2 m below the lowest fluid level.
 - Install a foot valve.
2. Supply operation:
 - Fluid level min. 0.5 above the center of the suction flange
 - Install a compensating line in the case of a supply container with vacuum pressure.

5.2.5 Optimizing changes in cross-section and direction

1. Avoid bending radii of less than 1.5 times the nominal pipe diameter.
2. Avoid abrupt changes of cross-section along the piping.

5.2.6 Optimizing supply ratios

- Ensure that $\text{NPSH}_{\text{system}} > \text{NPSH}_{\text{pump}}$ (\rightarrow data sheet):
 - in the case of the worst $\text{NPSH}_{\text{system}}$
 - at minimum pumping pressure

5.2.7 Providing safety and control devices (recommended)

Avoid impurities

1. Install a filter in the suction pipe, (mesh size of 0.1 mm.).
2. To monitor impurities, install a differential pressure gauge with a contact manometer.

Avoiding reverse running

- Install a slow-closing non-return member between the outlet flange and the gate valve to ensure that the pumped liquid does not flow back when the pump is switched off.

Avoiding excessive pressure

1. Provide appropriate pressure relief valves or other safety device in the pressure line.
2. Do **not** feed the return flow of the pressure relief valve directly back into the suction pipe.

Making provisions for isolating and shutting off pipes



For maintenance and repair work.

1. Provide shut-off devices in the suction and pressure pipes.
2. Recommended: Provide a means of emptying.

Allowing measurement of the operating conditions



WARNING

Material damage due to impermissible operating point!

- Include speed, pressure and temperature monitoring devices to ensure that the operating limits are observed.
-
1. Provide manometers for pressure measurements in the suction and pressure pipes.
 2. Provide load monitors (minimum and maximum load) on the motor side.
 3. Provide for pump-side temperature measurements.
 4. Provide a fill level indicator for the pump.

5.2.8 Installation recommendations




Fig. 9 Installation example

- A Head difference (with/without suction impeller)
- 1 Pump in suction operation
- 2 Suction strainer and non-return valve (foot valve)
- 3 Backflow preventer
- 4 Pump (without suction impeller) in supply operation
- 5 Filter/strainer
- 6 Pump (with suction impeller) in supply operation
- 7 Settling section

5.3 Installation on a foundation

DANGER

Risk of death and material damage due to magnetic field!

- ▶ Make sure that personnel who have a pacemaker do not perform any work on the pump.
- ▶ Secure the work area. If necessary isolate the area:
 - Make sure that personnel with pacemakers keep a safe distance of at least 1 meter.
 - Make sure that no magnetizable metal parts can be attracted by the magnetic coupling of the pump.
 - Make sure that parts of the magnetic coupling cannot be attracted by the magnetizable metal parts.
- ▶ Keep all magnetically-sensitive objects at a safe distance of at least 150 mm from the magnetic coupling.


NOTE

Material damage due to distortion of the base plate!

- ▶ Place the base plate on the foundation and fasten it as described below.

5.3.1 Preparing the pump unit


1. At pumped liquid temperatures of: $-20\text{ °C} < T < 120\text{ °C}$
 - Tighten the fastening screws of the pump feet on the drive end.
 - Tighten the fastening screws of the pump feet on the other end, but not so much as to prevent the pump from moving in a lateral direction.




2. At pumped liquid temperatures of: $T > 120\text{ °C}$ or $T < -20\text{ °C}$
 - Attach pump feet to the base plate on the side opposite the drive side using support sleeves.



5.3.2 Setting the pump unit on the foundation

- ✓ Aids, tools and materials:
 - Foundation bolts (not contained in the scope of delivery)
 - Steel washers
 - Non-shrinking mortar grout
 - Spirit level



1. Lift the pump unit (→ 4.1 Transport, Page 17).
 2. Attach the foundation bolts from below into the base plate fixing holes.
-  Observe the manufacturer's instructions when using adhesive anchors.
3. Set the pump unit down on the foundation. When doing so, sink the foundation bolts into the prepared anchoring holes.
 4. Use steel washers to align the pump unit to the height and system dimensions as described below:
 - Place a steel washer (2) to the left and right-hand side of each foundation bolt (1).
 - If the distance between the anchoring holes is greater than 750 mm, place additional steel washers (3) in the middle, on each side of the base plate.
 5. Make sure the steel washers lie flat against the base plate, in full contact.
 6. Use the integrated spirit level to check the maximum allowable tilt of 1 mm/m (end-to-end and side-to-side).
 7. Repeat the procedure until the base plate is correctly aligned.

5.3.3 Fastening the pump unit

-  Not necessary for block versions of pumps.
-  The damping behavior is improved by filling the base plate with mortar grout.

1. Fill the anchoring holes with mortar grout.
2. When the mortar grout has set, screw down the base plate at three points with the specified torque.
3. Before tightening the remaining bolts, compensate for any unevenness in the surface using metal spacing shims next to each bolt.
4. Fill the inside of the base plate with concrete, if intended. Knock on the base plate to ensure that no cavities are created in the process.
5. Make sure the base plate is not distorted.

5.4 Connecting the pipes

DANGER

Risk of death and material damage due to magnetic field!

- ▶ Make sure that personnel who have a pacemaker do not perform any work on the pump.
- ▶ Secure the work area. If necessary isolate the area:
 - Make sure that personnel with pacemakers keep a safe distance of at least 1 meter.
 - Make sure that no magnetizable metal parts can be attracted by the magnetic coupling of the pump.
 - Make sure that parts of the magnetic coupling cannot be attracted by the magnetizable metal parts.
- ▶ Keep all magnetically-sensitive objects at a safe distance of at least 150 mm from the magnetic coupling.


5.4.1 Keeping the pipes clean

NOTE

Material damage due to impurities in the pump!


- ▶ Make sure no impurities can enter the pump.
1. Clean all pipe parts and fittings prior to assembly.
 2. Ensure no flange seals protrude inwards.
 3. Remove any blank flanges, plugs, protective foils and/or protective paint from the flanges.

5.4.2 Installing auxiliary piping

-  Observe the manufacturers' specifications for any auxiliary operating systems which are present.


1. Connect the auxiliary pipes to the auxiliary connections so that they are stress-free and do not leak.
2. To avoid air pockets: Run the pipes with a continuous slope up to the pump.

5.4.3 Installing the suction pipe

-  Observe the arrow indicating the flow of direction.
If necessary, integrate a filter into the suction line to prevent impurities.

1. Remove the transport and sealing covers from the pump.
2. To avoid air pockets: Run the pipes with a continuous slope up to the pump.
3. Ensure no seals protrude inwards.
4. For suction operation: install a foot valve in the suction pipe to prevent the pump and suction pipe from running empty during downtimes.

5.4.4 Installing the pressure pipe

-  Observe the arrow indicating the flow of direction.

1. Remove the transport and sealing covers from the pump.
2. Run the pressure pipe with a continuous downward slope to the pump.
3. Ensure no seals protrude inwards.

5.4.5 Checking the stress-free pipe connections

- ✓ Piping installed and cooled down


NOTE

Material damage due to distorted pump casing!

- ▶ Ensure that all pipes are stress relieved when connected to the pump.

1. Disconnect the pipe connecting flanges from the pump.
2. Check whether the pipes can be moved freely in all directions within the expected range of expansion.
3. Make sure the flange surfaces are parallel.
4. Reconnect the pipe connecting flanges to the pump.

5.5 Installing the motor

-  Only necessary if the pump unit is assembled on site.


NOTE

Material damage caused by knocks and bumps!

- ▶ Keep the coupling halves properly aligned when slipping them on.
- ▶ Do not knock or hit any components of the pump.

1. Insert the shaft keys.
2. Slide on the pump-side and motor-side coupling halves until the shaft end is flush with the coupling hub. In doing so, maintain a clearance of 2–4 mm between the coupling halves.
3. Tighten the grub screws on both coupling halves.
4. Use suitable metal shims on the motor to align the end of the motor shaft to the end of the pump shaft.
5. Screw in the motor bolts, but do not tighten them yet (→ 5.7 Aligning the motor, Page 27).
6. Install the safety guarding.

5.6 Aligning the coupling precisely

 Only for horizontal versions.

DANGER

Risk of death due to rotating parts!

- Isolate the motor from its supply voltage and keep it locked when carrying out any fitting or maintenance work.

NOTE

Material damage due to incorrect alignment of the coupling!

- Align the motor exactly to the pump if there is any vertical, lateral or angular misalignment.
- For detailed information and special couplings (→ manufacturer's specifications).

Checking the alignment of the coupling

- ✓ Aids, tools and materials:
 - Feeler gauge
 - Straightedge
 - Dial gauge (for couplings with spacer piece)
 - Other suitable tools, e.g. laser alignment instrument




Fig. 10 Checking the alignment of the coupling

1. Measure in two planes at an angle of 90° on the circumference of the coupling.
2. Check the light gap towards the outer diameter using a straightedge (1):
 - Position the straightedge across both halves of the coupling.
 - Align the motor if there is a visible gap on the outer diameter (→ 5.7 Aligning the motor, Page 27).

3. Measure gap A with a feeler gauge (2):

| Size | Gap A [mm] | Lateral/vertical misalignment B [mm] | Angular displacement ¹⁾ [mm] |
|---------|------------|--------------------------------------|---|
| 1 (58) | 2 ... 4 | 0.15 | 0.15 |
| 2 (68) | 2 ... 4 | 0.15 | 0.15 |
| 3 (80) | 2 ... 4 | 0.15 | 0.15 |
| 4 (95) | 2 ... 4 | 0.20 | 0.20 |
| 5 (110) | 2 ... 4 | 0.20 | 0.20 |
| 6 (125) | 2 ... 4 | 0.20 | 0.20 |
| 7 (140) | 2 ... 4 | 0.20 | 0.20 |
| 8 (160) | 2 ... 6 | 0.25 | 0.25 |

Tab. 9 Coupling setting

- 1) $\text{Gap}_{\text{max}} - \text{Gap}_{\text{min}}$
 - Use the feeler gauge to measure the gap (A) between the coupling halves.
 - Align the motor if the gap is too wide (→ 5.7 Aligning the motor, Page 27).




Fig. 11 Checking for lateral and vertical misalignment

4. Check lateral or vertical misalignment B using the dial gauge:
 - Carry out the measurement as illustrated.
 - Align the motor if there is any lateral or vertical misalignment (→ 5.7 Aligning the motor, Page 27). Permissible axial or radial deviation, measured on the coupling front or circumference: < 0.05 mm




Fig. 12 Checking for angular displacement

5. Check the angular displacement with a dial gauge:
 - Permissible angular displacement (→ Table 9 Coupling setting, Page 26).
 - Carry out the measurement as illustrated.
 - If there is any angular displacement: align the motor (→ 5.7 Aligning the motor, Page 27).
6. Install the safety guarding properly.

5.7 Aligning the motor



- Only for horizontal versions. Alignment options:
- With sets of shims
 - With adjusting screws

5.7.1 Aligning the motor with sets of shims

1. Align the motor so that the coupling halves are exactly in line and fit shims if necessary.
2. Check the alignment.
3. Repeat the alignment procedure if there is still any vertical misalignment.
4. Then tighten the motor bolts.

5.8 Electrical connection

DANGER

Risk of death and material damage due to magnetic field!

- ▶ Make sure that personnel who have a pacemaker do not perform any work on the pump.
- ▶ Secure the work area. If necessary isolate the area:
 - Make sure that personnel with pacemakers keep a safe distance of at least 1 meter.
 - Make sure that no magnetizable metal parts can be attracted by the magnetic coupling of the pump.
 - Make sure that parts of the magnetic coupling cannot be attracted by the magnetizable metal parts.
- ▶ Keep all magnetically-sensitive objects at a safe distance of at least 150 mm from the magnetic coupling.

DANGER

Risk of death due to electric shock!

- ▶ Have all electrical work carried out by qualified electricians only.

DANGER

Risk of death due to rotating parts!

- ▶ Isolate the motor from its supply voltage and keep it locked when carrying out any fitting or maintenance work.
- ▶ Reinstall the safety guarding after all fitting and maintenance work.


5.8.1 Connecting the motor



- Follow the instructions of the motor manufacturer.

1. Connect the motor according to the connection diagram.
2. Make sure no danger arises due to electric power.
3. Install an EMERGENCY STOP switch.

6 Operation

 For pumps in explosion-hazard areas (→ 9.5 ATEX additional instructions, Page 46).

Short instructions for trained specialist personnel (→ 9.4 Short instructions for commissioning a pump unit delivered complete, Page 45).

6.1 Putting the pump into service for the first time

DANGER

Risk of death and material damage due to magnetic field!

- ▶ Make sure that personnel who have a pacemaker do not perform any work on the pump.
- ▶ Secure the work area. If necessary isolate the area:
 - Make sure that personnel with pacemakers keep a safe distance of at least 1 meter.
 - Make sure that no magnetizable metal parts can be attracted by the magnetic coupling of the pump.
 - Make sure that parts of the magnetic coupling cannot be attracted by the magnetizable metal parts.
- ▶ Keep all magnetically-sensitive objects at a safe distance of at least 150 mm from the magnetic coupling.

6.1.1 Performing the pressure test


NOTE

Material damage due to excessive pressure!


- ▶ Ensure that the test pressure does not exceed 1.3 times the nominal pressure of the pump (→ data sheet).
 - ▶ Ensure that the test pressure does not exceed 1.3 times the nominal pressure of the sealing system (→ data sheet).
 - ▶ If the test pressure is higher, remove the pump from the pressure test.
-
- ▶ Carry out the pressure test properly.

6.1.2 Identifying the pump type

- ▶ Identify the pump type (→ data sheet).


 The pump types vary e.g. with regard to the shaft seal or auxiliary systems.

6.1.3 Removing the preservative

 Only necessary for pumps treated for storage.

- ▶ (→ 4.4 Removing the preservative, Page 19).

6.1.4 Preparing auxiliary systems (if available)

 The manufacturer does not accept any liability for damage caused by installing or using a third-party or unapproved auxiliary system.

Sealing systems

1. Ensure that the sealing medium is suitable for mixing with the pumped liquid.
2. Install the sealing system (→ manufacturer's specifications).
3. Make sure the parameters required for the installed sealing system are met (→ manufacturer's specifications).

6.1.5 Filling and bleeding

- ✓ Auxiliary operating systems ready for operation

WARNING

Risk of injury and poisoning due to hazardous pumped liquids!

- ▶ Safely collect any leaking pumped liquid and dispose of it in accordance with environmental rules and requirements.

NOTE

Material damage caused by dry running!

- ▶ Make sure the pump is filled properly.
-
1. Fill the pump and the suction pipe with pumped liquid.
 - If pumped media are hot ($T > 100\text{ °C}$), ensure that the change in temperature of the pump housing is $< 10\text{ K/min}$.
 2. Open the suction-side fitting.
 3. Open the pressure-side fitting.
 4. If present: open the auxiliary systems and check the flow rate.
 5. Ensure that no pipe connections are leaking.

6.1.6 Checking the sense of rotation

- ✓ Pump filled and bled

DANGER

Risk of death due to rotating parts!

- ▶ Use personal protective equipment when carrying out any work on the pump.
- ▶ Keep an adequate distance to rotating parts.

NOTE

Material damage caused by dry running!

- ▶ Make sure the pump is filled properly.
1. Switch the motor on and immediately off again.
 2. Check whether the motor's sense of rotation is the same as that of the arrow on the pump.
 3. If the sense of rotation is different: Swap two phases (→ 5.8.1 Connecting the motor, Page 27).

6.2 Start-up

DANGER

Risk of death and material damage due to magnetic field!

- ▶ Make sure that personnel who have a pacemaker do not perform any work on the pump.
- ▶ Secure the work area. If necessary isolate the area:
 - Make sure that personnel with pacemakers keep a safe distance of at least 1 meter.
 - Make sure that no magnetizable metal parts can be attracted by the magnetic coupling of the pump.
 - Make sure that parts of the magnetic coupling cannot be attracted by the magnetizable metal parts.
- ▶ Keep all magnetically-sensitive objects at a safe distance of at least 150 mm from the magnetic coupling.

6.2.1 Switching on

- ✓ Pump set up and connected properly
- ✓ Motor set up and connected properly
- ✓ Motor exactly aligned with the pump
- ✓ All connections stress-free and sealed
- ✓ Any available auxiliary systems are ready for operation
- ✓ All safety equipment installed and tested for functionality
- ✓ Pump prepared, filled and bled properly
- ✓ Pump at rest (not running in reverse)

DANGER

Risk of injury due to running pump!

- ▶ Do not touch the running pump.
- ▶ Do not carry out any work on the running pump.
- ▶ Allow the pump to cool down completely before starting any work.

DANGER

Risk of injury and poisoning due to pumped liquid spraying out!

- ▶ Use personal protective equipment when carrying out any work on the pump.

NOTE

Material damage caused by dry running!

- ▶ Make sure the pump is filled properly.

NOTE

Risk of cavitation when throttling down the suction flow rate!

- ▶ Fully open the suction-side fitting and do not use it to adjust the flow rate.
- ▶ Do not open the pressure-side fitting beyond the operating point.

NOTE

Material damage caused by overheating!

- ▶ Do not operate the pump while the pressure-side fitting is closed.
- ▶ Observe the minimum flow rate (→ data sheet).

1. Open the suction-side fitting.
2. Open the pressure-side fitting.
3. Bypass line (if present):
 - Close it in suction operation during suction phase.
 - Open it during supply operation.
4. Switch on the motor and make sure it is running smoothly.
5. Once the motor has reached its nominal speed, close the pressure-side fitting slowly until the operating point is reached (→ data sheet).
6. Make sure any temperature changes at pumps with hot pumped liquids are below 10 K/min.
7. After the first load under pressure and at operating temperature, check that the pump is not leaking.
8. If the pumped liquid is hot, switch off the pump briefly at operating temperature, check the alignment of the coupling and realign the motor if necessary (→ 5.6 Aligning the coupling precisely, Page 26).
9. Switch the pump on and off a maximum of 10 times per hour.

6.2.2 Changing the operating parameters



When using the pump in boiler feed systems, note the following:

If the feed boiler is being operated temporarily with a lower operating pressure, the pump must be throttled down to the boiler's normal design operating pressure at the pressure side using a manual gate valve and a manometer attached at the outlet flange of the pump casing.

NOTE

Material damage caused by deviating operating parameters!

- ▶ Increasing the flow rate can cause cavitation.
- ▶ Pumped liquids with higher density require higher motor output and may overload the motor.

1. If the flow rate is increased, ensure that $NPSH_{system} > NPSH_{required}$ is observed.
2. If the density of the pumped liquid is increased, please ensure that the drive motor is not overloaded.

6.2.3 Switching off (temporarily)



WARNING

Risk of injury due to hot pump parts!

- ▶ Use personal protective equipment when carrying out any work on the pump.

1. If the pump remains under pressure while at rest: leave any auxiliary operating systems running.
2. Leave the bypass line open.
3. Switch off the motor.
4. Close the suction-side and pressure-side fittings when the motor has come to a standstill.
5. After initial start-up: Check all tie bolts and tighten them if necessary.

6.3 Shutting down the pump

DANGER

Risk of death and material damage due to magnetic field!

- ▶ Make sure that personnel who have a pacemaker do not perform any work on the pump.
- ▶ Secure the work area. If necessary isolate the area:
 - Make sure that personnel with pacemakers keep a safe distance of at least 1 meter.
 - Make sure that no magnetizable metal parts can be attracted by the magnetic coupling of the pump.
 - Make sure that parts of the magnetic coupling cannot be attracted by the magnetizable metal parts.
- ▶ Keep all magnetically-sensitive objects at a safe distance of at least 150 mm from the magnetic coupling.

WARNING

Risk of injury and poisoning due to hazardous pumped liquids!

- ▶ Safely collect any leaking pumped liquid and dispose of it in accordance with environmental rules and requirements.

1. During supply operation, close the suction-side fitting.
2. Auxiliary operating systems
 - If the pump remains under pressure: leave it running
 - If fluid is being supplied from vacuum systems: leave it running
 - If running in parallel with a shared suction pipe: leave it running
 - Otherwise: shut it off

3. Take the following measures whenever the pump is shut down:

| Pump is | Measure |
|-------------------------------------|---|
| ...shut down for a prolonged period | ▶ Take measures according to the pumped liquid (→ Table 11 Measures depending on the behavior of the pumped liquid, Page 31). |
| ...emptied | ▶ Close the suction-side and pressure-side fittings. |
| ...dismounted | ▶ Isolate the motor from its power supply and secure it against unauthorized switch-on. |
| ...put into storage | ▶ Follow the storage instructions (→ 4.3 Storage, Page 18). |

Tab. 10 Measures to be taken if the pump is shut down

| Behavior of the pumped liquid | Duration of shutdown (depending on process) | |
|--|---|--|
| | Short | Long |
| Elements of the pumped liquid sediment or crystallize. | ▶ Flush the pump. | ▶ Flush the pump. |
| Solidifying/ freezing, non-corrosive | ▶ Heat up or empty the pump and containers. | ▶ Empty the pump and containers. |
| Solidifying/ freezing, corrosive | ▶ Heat up or empty the pump and containers. | ▶ Empty the pump and containers. ▶ Treat the pump and containers with preservative. |
| Remains liquid, non-corrosive | – | – |
| Remains liquid, corrosive | – | ▶ Empty the pump and containers. ▶ Treat the pump and containers with preservative. |

Tab. 11 Measures depending on the behavior of the pumped liquid

6.4 Start-up following a shutdown period

DANGER

Risk of death and material damage due to magnetic field!

- ▶ Make sure that personnel who have a pacemaker do not perform any work on the pump.
- ▶ Secure the work area. If necessary isolate the area:
 - Make sure that personnel with pacemakers keep a safe distance of at least 1 meter.
 - Make sure that no magnetizable metal parts can be attracted by the magnetic coupling of the pump.
 - Make sure that parts of the magnetic coupling cannot be attracted by the magnetizable metal parts.
- ▶ Keep all magnetically-sensitive objects at a safe distance of at least 150 mm from the magnetic coupling.

1. If the pump is shut down for over 1 year, take the following measures before restoring it to service:

| Shutdown period | Measure |
|-----------------|---|
| > 1 year | ▶ Check antifriction bearings and replace if necessary. |
| > 2 years | ▶ Replace the elastomer seals (O-rings, shaft sealing rings). ▶ Replace the antifriction bearings. |


Tab. 12 Measures to be taken after prolonged shutdown periods


2. Carry out all steps as for the initial start-up (→ 6.1 Putting the pump into service for the first time, Page 28).

6.5 Operating the stand-by pump

- ✓ Stand-by pump filled and bled
- ▶ Operate the stand-by pump at least once a week (→ 6.1 Putting the pump into service for the first time, Page 28).


7 Maintenance

 For pumps in explosion-hazard areas (→ 9.5 ATEX additional instructions, Page 46).

 Trained service technicians are available for fitting and repair work. Present a pumped liquid certificate (DIN safety data sheet or safety certificate) when requesting service.

2. For trouble-free operation, always ensure the following:
 - No dry running
 - No leaks
 - No cavitation
 - Suction-side gate valves open
 - Sufficient suction pressure
 - No unusual running noises or vibrations
 - Magnet coupling may not break off
 - Proper functioning of auxiliary systems

7.1 Inspections

 The inspection intervals depend on the operational strain on the pump.

DANGER

Risk of death and material damage due to magnetic field!

- ▶ Make sure that personnel who have a pacemaker do not perform any work on the pump.
- ▶ Secure the work area. If necessary isolate the area:
 - Make sure that personnel with pacemakers keep a safe distance of at least 1 meter.
 - Make sure that no magnetizable metal parts can be attracted by the magnetic coupling of the pump.
 - Make sure that parts of the magnetic coupling cannot be attracted by the magnetizable metal parts.
- ▶ Keep all magnetically-sensitive objects at a safe distance of at least 150 mm from the magnetic coupling.

DANGER

Risk of injury due to running pump!

- ▶ Do not touch the running pump.
- ▶ Do not carry out any work on the running pump.

WARNING

Risk of injury and poisoning due to hazardous pumped liquids!

- ▶ Use personal protective equipment when carrying out any work on the pump.

1. Check at appropriate intervals:
 - Adherence to the minimum and maximum flow rates
 - Temperature of antifriction bearings < 80 °C measured at the bearing housing)
 - Normal operating conditions unchanged (differential head, speed, etc.)
 - If present, make sure the pressure relief valve is functioning properly
 - Coupling alignment and condition of elastic parts
 - Filling level in the suction or supply container
 - Filters and strainers (if present)

7.2 Maintenance

i Service life of the antifriction bearings for operation within the permissible operating range: > 2 years

Intermittent operation, high temperatures, low viscosities and aggressive ambient and process conditions reduce the service life of antifriction bearings.

i Mechanical seals are subject to natural wear, which strongly depends on the respective operating conditions. Therefore, general statements regarding their service life cannot be made.

⚠ DANGER

Risk of death and material damage due to magnetic field!

- ▶ Make sure that personnel who have a pacemaker do not perform any work on the pump.
- ▶ Secure the work area. If necessary isolate the area:
 - Make sure that personnel with pacemakers keep a safe distance of at least 1 meter.
 - Make sure that no magnetizable metal parts can be attracted by the magnetic coupling of the pump.
 - Make sure that parts of the magnetic coupling cannot be attracted by the magnetizable metal parts.
- ▶ Keep all magnetically-sensitive objects at a safe distance of at least 150 mm from the magnetic coupling.

⚠ DANGER

Risk of injury due to running pump!

- ▶ Do not touch the running pump.
- ▶ Do not carry out any work on the running pump.
- ▶ Isolate the motor from its supply voltage and keep it locked when carrying out any fitting or maintenance work.

⚠ DANGER

Risk of death due to electric shock!

- ▶ Have all electrical work carried out by qualified electricians only.

⚠ WARNING

Risk of injury and poisoning due to hazardous or hot pumped liquids!

- ▶ Use personal protective equipment when carrying out any work on the pump.
- ▶ Allow the pump to cool down completely before commencing any work.
- ▶ Make sure the pump is depressurized.
- ▶ Empty the pump, safely collect the pumped liquid and dispose of it in accordance with environmental regulations.

7.2.1 Bearing

1. As a precaution, replace antifriction bearings with lifetime lubrication every 2 years (recommended).
2. As a precautionary measure, replace the low-friction carbon bush every 2 years (recommended).


7.2.2 Mechanical seals

i Mechanical seals will always leak a bit, due to the way they work.

- ▶ In the event of major leaks: replace the mechanical seals and their auxiliary seals and check the integrity of the auxiliary systems.

7.2.3 Coupling

1. Check the condition of the coupling and of elastic parts every 1,000 operating hours.



2. Check for coupling wear every 1,000 operating hours.
 - Turn the coupling halves in opposite directions.
 - Mark the position with a pen above both halves of the coupling.
 - Turn the coupling halves in the opposite direction.
 - Mark the position with a pen above both halves of the coupling.
 - Measure distance ΔS between the two markings.

| Size | ΔS wear |
|------|-----------------|
| 58 | 5.5 |
| 68 | 5.5 |
| 80 | 5.0 |
| 95 | 6.0 |
| 110 | 7.0 |
| 125 | 8.0 |
| 140 | 8.0 |
| 160 | 8.0 |

Tab. 13 Coupling wear

3. Check the coupling alignment and realign the motor if necessary (→ 5.6 Aligning the coupling precisely, Page 26).


7.2.4 Cleaning the pump

NOTE

High water pressure or spray water can damage bearings!

- ▶ Do not clean bearing areas with a water or steam jet.
- ▶ Clean large-scale grime from the pump.

7.3 Dismounting

 Trained service technicians are available for fitting and repair work. When requesting service, present a pumped medium certificate – DIN safety data sheet or document of compliance (→ 9.2 Safety certificate, Page 42). Repair instructions can be ordered with spare parts if carrying out the repair work yourself.

DANGER

Risk of death and material damage due to magnetic field!

- ▶ Make sure that personnel who have a pacemaker do not perform any work on the pump.
- ▶ Secure the work area. If necessary isolate the area:
 - Make sure that personnel with pacemakers keep a safe distance of at least 1 meter.
 - Make sure that no magnetizable metal parts can be attracted by the magnetic coupling of the pump.
 - Make sure that parts of the magnetic coupling cannot be attracted by the magnetizable metal parts.
- ▶ Keep all magnetically-sensitive objects at a safe distance of at least 150 mm from the magnetic coupling.

DANGER

Risk of injury due to running pump!

- ▶ Do not touch the running pump.
- ▶ Do not carry out any work on the running pump.
- ▶ Isolate the motor from its supply voltage and keep it locked when carrying out any fitting or maintenance work.

DANGER

Risk of death due to electric shock!

- ▶ Have all electrical work carried out by qualified electricians only.

WARNING

Risk of injury and poisoning due to hazardous or hot pumped liquids!

- ▶ Use personal protective equipment when carrying out any work on the pump.
- ▶ Allow the pump to cool down completely before commencing any work.
- ▶ Make sure the pump is depressurized.
- ▶ Empty the pump, safely collect the pumped liquid and dispose of it in accordance with environmental regulations.

WARNING

Risk of injury due to heavy components!

- ▶ Pay attention to the component weight. Lift and transport heavy components using suitable lifting gear.
- ▶ Set down components safely and secure them against overturning or rolling away.

WARNING

Risk of injury during disassembly!

- ▶ Secure the pressure-side and suction-side gate valves against accidental opening.
- ▶ Wear protective gloves as components can become very sharp through wear or damage.
- ▶ Remove spring-loaded components carefully (e.g. mechanical seal, tensioned bearing, valves etc.), as components can be ejected by the spring tension.
- ▶ Observe the manufacturer's specifications (e.g. for the motor, coupling, mechanical seal, blocking pressure system, cardan shaft, drives, belt drive etc.).

NOTE

Material damage, breakable components!

- ▶ Dismount ceramic parts on the sleeve bearings and magnet coupling carefully (do not allow them to hit anything).

7.3.1 Dismounting

- ✓ Pump depressurized
- ✓ Pump completely empty, flushed and decontaminated
- ✓ Electrical connections disconnected and motor secured against being switched on again
- ✓ Pump cooled down
- ✓ Deinstall the safety guarding.
- ✓ On couplings with spacer piece: spacer piece removed
- ✓ Auxiliary systems shut down, depressurized and emptied
- ✓ Manometer lines, manometer and holdings dismantled
- ▶ Observe the following during removal:
 - Mark the precise orientation and position of all components before dismantling them.
 - Dismount components concentrically (axially) without canting, starting with the suction side.
 - Dismount the pump (→ sectional drawing).
 - The assembly/disassembly instructions can be requested from the manufacturer if required.


7.3.2 Returning the pump to the manufacturer

1. Enclose a truthfully and fully completed safety certificate when returning pumps or components to the manufacturer. Safety certificates can be ordered from the manufacturer, if necessary.
2. Take necessary measures, depending on the required repair work, as listed in the table below when returning the pump to the manufacturer.

| Repairs | Measure for return |
|--|--|
| ...at the customer's premises | ▶ Return the defective component to the manufacturer. |
| ...at the manufacturer's premises | ▶ Flush the pump and decontaminate it if it was used for hazardous pumped liquids. ▶ Return the complete pump (not disassembled) to the manufacturer. |
| ...at the manufacturer's premises for warranty repairs | ▶ Only in the event of hazardous pumped liquid: flush and decontaminate the pump. ▶ Return the complete pump (not disassembled) to the manufacturer. |

Tab. 14 Measures for returning the pump

7.4 Installing

-  Reinstall the components concentrically, without canting, in accordance with the marks applied.

DANGER

Risk of death and material damage due to magnetic field!

- ▶ Make sure that personnel who have a pacemaker do not perform any work on the pump.
- ▶ Secure the work area. If necessary isolate the area:
 - Make sure that personnel with pacemakers keep a safe distance of at least 1 meter.
 - Make sure that no magnetizable metal parts can be attracted by the magnetic coupling of the pump.
 - Make sure that parts of the magnetic coupling cannot be attracted by the magnetizable metal parts.
- ▶ Keep all magnetically-sensitive objects at a safe distance of at least 150 mm from the magnetic coupling.

WARNING

Risk of injury due to heavy components!

- ▶ Pay attention to the component weight. Lift and transport heavy components using suitable lifting gear.
- ▶ Set down components safely and secure them against overturning or rolling away.

WARNING

Risk of injury during assembly!

- ▶ Install spring-loaded components carefully (e.g. mechanical seal, tensioned bearing, valves etc.), as components can be ejected by the spring tension.
- ▶ Observe the manufacturer's specifications (e.g. for the motor, coupling, mechanical seal, blocking pressure system, cardan shaft, drives, belt drive etc.).

NOTE

Material damage due to unsuitable components!

- ▶ Always replace lost or damaged screws with screws of the same strength.
- ▶ Only replace seals with seals of the same material.

1. Observe the following during installation:
 - Replace worn parts with genuine spare parts.
 - Replace seals.
 - Observe prescribed tightening torques (these can be requested from the manufacturer if required).
2. Clean all parts. Do not remove any markings that may have been attached.
3. Install the pump (→ sectional drawing).
 - The assembly/disassembly instructions can be requested from the manufacturer if required.
4. Replace/reactivate all safety and protective devices.
5. Install the pump in the system (→ 5 Setup and connection, Page 20).

7.5 Ordering spare parts

- ▶ Have the following information ready to hand when ordering spare parts (→ 3.1.1 Type plate, Page 9).
 - Name
 - Serial number
 - Year of manufacture
 - Part number
 - Designation
 - Quantity
 - Delivery type
 - Delivery address

8 Troubleshooting

DANGER

Risk of death and material damage due to magnetic field!

- ▶ Make sure that personnel who have a pacemaker do not perform any work on the pump.
- ▶ Secure the work area. If necessary isolate the area:
 - Make sure that personnel with pacemakers keep a safe distance of at least 1 meter.
 - Make sure that no magnetizable metal parts can be attracted by the magnetic coupling of the pump.
 - Make sure that parts of the magnetic coupling cannot be attracted by the magnetizable metal parts.
- ▶ Keep all magnetically-sensitive objects at a safe distance of at least 150 mm from the magnetic coupling.

8.1 Pump malfunctions

If malfunctions occur which are not specified in the following table or cannot be traced back to the specified causes, please consult the manufacturer.

| Malfunction | Possible cause | Remedy |
|-----------------------|--|---|
| Delivery rate too low | Counter-pressure too high | ▶ Reset operating point. |
| | Suction head too high, or supply head too low. | ▶ Check the liquid level. ▶ Completely open the suction-side fittings. |
| | Blocked filter NPSH has not been observed. | ▶ Clean the filters and dirt traps on the suction side. |
| | Gaps in sealing have become too large due to wear. | ▶ Replace the worn pump parts. |
| | Incorrect sense of rotation or rotational speed | ▶ Connect motor properly. |
| | Housing or suction line leaky | ▶ Replace the housing seal. ▶ Check the flange connections. |
| No pump suction | Suction line or shaft seal on suction side leaky | ▶ Replace the housing seal. ▶ Check the flange connections. |
| | Suction head excessive | ▶ Check the liquid level. |
| | Gaps between impeller and stage too large due to wear and tear | ▶ Replace the worn pump parts. |
| | Incorrect sense of rotation | ▶ Connect motor properly. |
| | Fluid reserve in pump too low | ▶ Fill the pump. |
| | Suction or pressure gate valve closed | ▶ Open the gate valve. |
| | Incorrect pipe connection | ▶ Connect pump properly. |
| | Incorrect electrical connection | ▶ Connect motor properly. |
| | NPSH has not been observed. | ▶ Clean the filters and dirt traps on the suction side. |
| | Screw plugs still in place | ▶ Remove the screw plugs. |


| Malfunction | Possible cause | Remedy |
|----------------------------------|---|---|
| Pump leaking | Housing screw joints leaky | ▶ Check the tightening torque of the housing screw joints and correct if necessary. |
| | Pump is distorted. | ▶ Check that piping is stress-free. |
| | Seals faulty | ▶ Replace seals. |
| Temperature increase in the pump | Pump or pipe not filled completely | ▶ Bleed and fill pump and suction and supply lines. |
| | Suction head too high, or supply head too low. | ▶ Check the liquid level. ▶ Open the suction-side shut-off devices. |
| | Pump running dry | ▶ Clean the filters and dirt traps on the suction side. |
| Pump running roughly or noisily | Suction head too high, or supply head too low (cavitation). | ▶ Check the liquid level. ▶ Open the suction-side shut-off devices. |
| | Q_{\min} is below the minimum | ▶ Clean the filters and dirt traps on the suction side. |
| | Pump or pipe not filled completely or pump is cavity | ▶ Bleed and fill pump and suction and supply lines. |
| | Pump is cavitating | ▶ Check supply ratios, supply pressure and temperature of pumped medium ($NPSH_{\text{pump}} < NPSH_{\text{system}}$) |
| | The existing max. torque of the magnetic coupling was exceeded, i.e. the magnetic coupling has been torn off. | ▶ Check whether the pump has been blocked by contaminants (pump running smoothly). ▶ Check the internal sleeve bearings. ▶ Check the operating conditions (→ data sheet). ▶ Check the maximum permissible density of the pumped liquid (→ data sheet). |
| | Pump is not positioned evenly on the ground or is distorted. | ▶ Check the pump setup. |
| | Foreign particles in the pump | ▶ Dismantle and clean the pump. |
| | Coupling worn and/or aligned incorrectly | ▶ Check for wear and tear and check the coupling alignment. |
| | Motor running on 2 phases | ▶ Check pipe insulation and connections, as well as the fuse. |
| | Antifriction bearing defective | ▶ Check that the pump is running smoothly. |

| Malfunction | Possible cause | Remedy |
|---|---|--|
| Motor protection switch moves to off position | Foreign particles in the pump | ► Dismantle the pump and replace damaged parts. |
| | Closed gate valve in the pressure line | ► Open the gate valve. |
| | Permissible pumping conditions are not being observed. | ► Check the operating conditions (→ data sheet). |
| | Power consumption is greater than the top limit value. | ► Check the motor protection switch and the electrical connection. |
| | Friction increase in the pump | ► Check the following conditions: <ul style="list-style-type: none"> • Pump blocked by contaminants • Shaft bearing worn • Stuffing box bolted too tightly • Viscosity and/or density of pumped liquid increased |
| No pumping action, although motor is running | The existing max. torque of the magnetic coupling was exceeded, i.e. the magnetic coupling has been torn off. | <ul style="list-style-type: none"> ► Check whether the pump has been blocked by contaminants (pump running smoothly). ► Check the internal sleeve bearings. ► Check the operating conditions (→ data sheet). ► Check the maximum permissible density of the pumped liquid (→ data sheet). ► Check the arrangement of the magnetic coupling – motor – pump (→ data sheet). |


Tab. 15 Troubleshooting list

9 Appendix

9.1 Technical specifications

 Further technical specifications (→ data sheet)

9.1.1 Ambient conditions

 Operation under any other ambient conditions should be agreed with the manufacturer.

| Temperature [°C] | Relative humidity [%] | |
|------------------|-----------------------|------------|
| | Long-term | Short-term |
| 20 to 40 | ≤ 85 | ≤ 100 |

Tab. 16 Ambient conditions

9.1.2 Weight

(→ Delivery note)

9.1.3 Sound pressure level

Expected noise levels for side channel pumps at a speed of $n = 1450 \text{ min}^{-1}$.




Fig. 13 Sound pressure level

9.2 Safety certificate



Please copy this document and send it together with the pump.

| | |
|---|---|
| The pump and accessories submitted for inspection / repairs together with the safety certificate by us, the signatory: | |
| Type: _____ | Delivery date: _____ |
| Part no.: _____ | Order no.: _____ |
| Reason for inspection / repair: _____ | |
| <div style="display: flex; align-items: flex-start;"> <div style="margin-right: 10px;"> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> <input type="checkbox"/> </div> <div> <p>Was not used with liquids that are hazardous to health or the environment.</p> <p>Was used for the following application: _____</p> <p>and came into contact with liquids that must be labeled for safety or are considered to be polluting.</p> <p>Last pumped liquid: _____</p> <p>The pump has been carefully emptied and cleaned on the outside and inside prior to delivery or provision.</p> <p>Special safety precautions are not necessary for subsequent handling.</p> <p>The following safety precautions regarding rinsing liquids, liquid residue and disposal are necessary:</p> <p>_____</p> </div> </div> <div style="margin-top: 20px;"> <p>If the pump was used with critical liquids, please make sure you enclose a safety data sheet in the package.</p> </div> | |
| <p>We hereby declare that the information given is correct and complete, and that the pump is being shipped in accordance with legal requirements.</p> | |
| Company / address: _____ | Phone: _____ Fax: _____ |
| Customer no.: _____ | |
| Issuer name: (capital letters) _____ | Position: _____ |
| Date: _____ | Company stamp / signature: _____ |

Tab. 17 Safety certificate

9.3 Declarations according to EC machine directives

9.3.1 Declaration of conformity according to EC machine directives

Declaration of conformity to EC Machine Directive 2006 / 42 / EC, Appendix II 1A

We hereby declare that the design and layout of the machine described below, as well as the variant thereof put into circulation by us, conforms to the relevant basic safety and health protection requirements of the EC Machine Directive.

If any unauthorized changes or made to the unit, and/or it is used in a manner other than that intended, this declaration loses its validity.

Pump unit for pumping fluids

Description/series _____

Serial number _____

Relevant regulations:

- Machine Directive (2006/42/EC)

Applicable harmonized norms:

- EN 809:1998
- EN ISO 12100-1:2004
- EN ISO 12100-2:2004
- EN ISO 14121-1:2007

Date: 12/29/2009

The officer responsible for documentation compiles the technical documents.

Tab. 18 Declaration of conformity according to EC machine directives

9.3.2 Declaration of installation according to EC machine directive

Declaration of installation

conforming to EC Machine Directive 2006 / 42 / EC , Appendix II 1B

We hereby declare that the incomplete machine described below is intended to be fitted into a machine/joined to other machines. Basic safety and health protection requirements of the EC Machine Directive are applicable and are complied with. The special technical documents have been drawn up in accordance with Appendix VII, Part B. The incomplete machine may not be commissioned until it has been established that the machine into which the incomplete machine is to be fitted complies with the provisions of EC Machine Directive 2006 / 42 / EC.

Pump unit for pumping fluids

Description/series _____

Serial number _____

The following basic safety and health protection requirements (2006 / 42 / EC, Appendix I) are complied with:

- 1.1.2. – Principles of safety integration a) to d)
- 1.1.3 – Materials and products
- 1.1.5. – Design of machinery to facilitate its handling

Applicable harmonized norms:

- EN 809:1998
- EN ISO 12100-1:2004
- EN ISO 12100-2:2004
- EN ISO 14121-1:2007

Date: 29.12.2009

The officer responsible for documentation compiles the technical documents.
If a reasonable request is made by national authorities, we undertake to supply the special technical documents in printed form by courier.

Tab. 19 Declaration of installation according to EC Machine Directive

9.4 Short instructions for commissioning a pump unit delivered complete



Danger of death!

- Read and observe the complete operating manual, in particular the warning notices and the general safety notices.

Preparing the pump unit:

- Pumped medium
 - may not crystallize
 - no solids with an aggressive effect
- Remove the blind plugs before connecting the pipes.
- If the pump has been treated:
 - drain preservative
 - dispose of preservative properly
 - clean the pump

Installing the pump unit:

- Align the pump unit on the foundation and fix it in place.
- Clean and connect pipes, observing the sense of flow and rotation (see arrows on pump).

Starting-up the pump unit:

- Fill the pump with liquid (pump must have been bled completely).
- Open all shut-off fittings in the suction and pressure pipes.
- Check that the safety guarding is installed and that all safety devices are operational.
- The electrical connection must be established by a qualified electrician!
 - Provide a motor protection switch
 - Check the voltage, speed and sense of rotation.
- Turn the unit by hand and make sure that it turns easily and evenly.
- Switch on the motor.
- After powering up to operational speed, check the operational pressure at the manometer. If necessary, adjust the operating point by throttling the pressure side.

Operating the pump unit

- The flow rate may not drop below the minimum.
- Fluid must flow into the pump at all times: It cannot be allowed to run dry!
- Never touch a pump while it is in operation, as it could be hot/cold.
- Power consumption increases as the differential head increases and the flow rate decreases.
- Pipes may not transmit electrical voltage to the pump, either during assembly or during operation.

9.5 ATEX additional instructions

Additional requirements for safe operation in areas at risk of explosion.

9.5.1 Safety

Intended use

The pump, as non-electrical equipment, satisfies the device requirements for equipment in equipment group II, categories 2 and 3.

Do not use pump if

- any valves are closed.
- the operating range is exceeded in any way (→ data sheet).
- the maintenance interval has been exceeded.

Obligations of the operating company

- Evaluate and document the operating areas of the system for danger of explosions in accordance with Directive 94/9/EC, appendix I.
- Ensure that Directive 99/92/EC is observed to protect the health and safety of employees in potentially explosive atmospheres.
- Only operate the pump according to the explosion protection labeling.
- Always ensure that the following conditions are met:
 - the pump is earthed.
 - there is no contact between the coupling and the safety guarding.
 - pump interior, seal chamber, auxiliary systems and vacuum and pressure pipes are always completely filled with the liquid being transported.
 - the maximum permissible surface temperature of the pump is not exceeded.
 - fittings on the suction and pressure side of the pump are set correctly.
 - the pump is regularly maintained and monitored.
 - dry running must be prevented under all circumstances, e.g. by use of level monitoring or a flow indicator.
- Ensure that the motors, couplings and monitoring units supplied on site actually correspond to the category and temperature class of the associated zone.
- Note the data sheet supplied.
- Inform personnel about special dangers:
 - Danger of explosions when removing dust build-up

Materials and pumped liquids

Ensure that:

- all components are electrically conductive.
- the build up of static electricity is avoided: Only use pumped liquids with a conductivity $> 10^{-8}$ S/m.

9.5.2 Explosion protection mark

Labeling


 The pump is labeled as follows:
temperature class (→ data sheet)




Fig. 14 Explosion protection labeling on the pump (equipment group II, category 2)



Fig. 15 Explosion protection labeling on the pump (equipment group II, category 3)

- 1 CE labeling
- 2 Symbol for explosion protected equipment
- 3 Equipment group
- 4 Category
- 5 Ex atmosphere
- 6 Type of protection against ignition
- 7 Temperature class (x = 1 – 4)


Temperature class

 Flammable gases and vapors are divided into temperature classes for their inflammability on hot surfaces.

The surface temperature of the pump must always be less than the lowest ignition temperature of the temperature class.

| Temperature class | Ignition temperature range for mixture [°C] | Maximum surface temperature [°C] |
|-------------------|---|----------------------------------|
| T1 | > 450 | 450 |
| T2 | $> 300 \leq 450$ | 300 |
| T3 | $> 200 \leq 300$ | 200 |
| T4 | $> 135 \leq 200$ | 135 |
| T5 | $> 100 \leq 135$ | 100 |
| T6 | $> 85 \leq 100$ | 85 |

Tab. 20 Temperature class

 The pump may only be operated up to the temperature class specified on the type plate.

Type of protection against ignition

The **type of protection against ignition** describes the type of measures used to prevent ignition in a potentially explosive atmosphere.

| Type of protection against ignition | Meaning | For an area | |
|-------------------------------------|----------------------------|-------------------------------|---------------------------|
| | | with non electrical equipment | with electrical equipment |
| b | Ignition source monitoring | X | – |
| c | Safe design | X | – |
| k | Liquid encapsulation | X | – |

Tab. 21 Type of protection against ignition

Ex atmosphere

The **Ex atmosphere** describes the type of potentially explosive atmosphere in a zone.

| Ex atmosphere | Meaning |
|---------------|----------------------------|
| G | Flammable gases and vapors |

Tab. 22 Ex atmosphere

Equipment group / area of use / zone / category

Pumps are divided by area of use into **equipment groups** and **categories**.

The **zone** depends on the probability of occurrence of a potentially explosive atmosphere and differentiates between gases and dusts.

The **category** describes the safe design of the pump and depends on the zone.

| Equipment group / area of use | Zone | Category | Frequency of occurrence of dangerous, potentially explosive atmospheres | Safe design |
|-------------------------------|-----------------|----------|---|-------------|
| II / other | 1 (G) 21 (D) | 2 | occasionally (any faults occurring may not become a source of ignition) | high |
| II / other | 2 (G) 22 (D) | 3 | unlikely; if it does occur, then rarely and short-term (in normal operation, surface temperature may not become source of ignition in normal operation) | normal |

Tab. 23 Equipment group / area of use / zone / category

9.5.3 Installation and connection



The measures to install and connect depend upon the category (→ 9.5.2 Explosion protection mark, Page 46).

Basic measures

- Only use contact guards made from electrically conductive components.
- Secure the grub screw to fix the coupling halves with Loctite (medium strength).
- For aluminum safety guarding:
 - Remove swarf and dirt from the safety guarding.
- For pumps with motors supplied by the operator:
 - Motor must correspond to the requirements (group, category) in explosion-hazard areas.
- Install a slow-closing non-return member between the outlet flange and the gate valve to ensure that the pumped liquid does not flow back when the pump is switched off.
- If a frequency converter is used:
 - Check with the pump manufacturer whether it may be used.

Measures for category 2 equipment

Ensure there is monitoring equipment to prevent overheating due to dry running.

| Type and design of the shaft seal ¹⁾ | Measure |
|---|--|
| Single mechanical seal | <p>If the pumped liquid contains gas:</p> <ul style="list-style-type: none"> ▶ Make sure that the following parts for measuring the temperature on the counter ring of the mechanical seal meet the requirements of the 94/9/EC Directive: <ul style="list-style-type: none"> – Temperature sensor on the counter ring of the mechanical seal – Temperature monitoring device ▶ If necessary, fit appropriate temperature gauges. |
| Double mechanical seal arranged back-to-back | <ul style="list-style-type: none"> ▶ Include a pressure gauge for the sealing medium. |
| Double mechanical seal in tandem arrangement | <ul style="list-style-type: none"> ▶ If necessary, fit level measurement device for the supply container. ▶ If the temperature difference between sealing medium and temperature class < 15 Kelvin: Include a temperature gauge for the barrier medium. |
| Single mechanical seal with quench and a secondary seal with lip seal | |
| Magnetic coupling | <ul style="list-style-type: none"> ▶ Include the following monitoring devices: <ul style="list-style-type: none"> – Motor load monitor – Separating can temperature monitor – Fill level monitor |

Tab. 24 Possible control measures to avoid dry running with resulting impermissible overheating

1) (→ data sheet)

Monitor the system according to the behavior of the parameters:

| Parameters ¹⁾ | Measure |
|---------------------------|--|
| Constant | <ul style="list-style-type: none"> ▶ Monitor the motor power: <ul style="list-style-type: none"> – Reaction time < 5 s – Accuracy < 15% – Recording of active power of all three phases – Monitoring of excessive and insufficient load (→ data sheet) ▶ Alternatively: Monitor the flow rate and/or tank level |
| At least one not constant | <ul style="list-style-type: none"> ▶ Monitor the flow rate and/or tank level <ul style="list-style-type: none"> – Reaction time < 5 s – Monitoring of minimum and maximum load (→ data sheet) |

Tab. 25 Measures to prevent impermissible overheating

1) Flow rate, differential head, density, viscosity, speed of rotation, flow quantity

Adhere to the requirements for ignition source monitoring

Ensure that ignition source monitoring complies with the minimum ignition protection level (IPL) requirements according to DIN EN 13463-6:

- IPL 1 for category 2

9.5.4 Operation

Staying within maximum permissible operating temperatures

Stay within the maximum permissible operating temperature of the pump (→ pump data sheet):


Staying within the maximum permissible temperature of the pumped liquid

| Temperature class | Permissible temperature of the pumped medium [°C] ¹⁾ |
|-------------------|---|
| T4 | 80 |
| T3 | 145 |
| T2 | 240 |
| T1 | 390 |

Tab. 26 Max. pumped liquid temperature

1) Applies to specific heat capacity of water ($c_{\text{water}} = 4.2 \text{ KJ/kgK}$) and at speeds < 1450 min⁻¹

Staying within the maximum permissible temperature of the heating medium

 Agree electrically operated heating systems with the manufacturer.

Stay within maximum permissible temperature of the heating medium (→ table):

- Compare the value in the table with the maximum permissible temperature of the housing surface.
- Use the lower value as the maximum permissible value.

| Temperature class | Permissible temperature of the heating medium [°C] ¹⁾ |
|-------------------|--|
| T4 | 80 |
| T3 | 145 |
| T2 | 220 |
| T1 | 220 |

Tab. 27 Max. heating medium temperature

Safe operation

Ensure the following operating conditions:

- No dry running
- Do not run overloaded
- Do not run while suction-side fittings are closed
- Do not run while pressure-side fittings are closed (even briefly while powering up)
- Bleed the mechanical seal area regularly

9.5.5 Maintenance



Maintenance intervals are reduced for more difficult operating conditions.

Carrying out measures

Change the motor antifriction bearings as specified by the manufacturer.

Change pump bearings after 10,000 hours.

Check at appropriate intervals (monthly at least):

- the motor and coupling according to the manufacturer's operating instructions
- Surface temperatures of motor and pump
- Changes to running noises or vibrations
- Deformation of the safety guarding and spacing to the rotating parts
- the functioning of the monitoring devices

